



PART DETAILS			
ITEM	STOCK NUMBER	DESCRIPTION	COMMENTS
1	AQ21	Schlegel Aquamac Perimeter Seal	
2	DS 30 x 18 mm FRR	Door Stop	To suit AQ21 Seal
3	IS	20 x 4 mm Intumescent Strip	
4	IS Mastic	Intumescent Liquid Application Mastic	If wall has cladding, Mastic must be deeper than cladding (min. 20mm depth)
5	J1 FRR	J1 Jamb, 30 mm Pine	92-600mm wide available
6	PEF Rod	Polyurethane Foam Backing Rod	Diameter to exceed gap width
7	WB	Wedging Block	Cut to suit
8	ANC	Dynabolt	Ramset Dynabolt M10 x 100mm or equivalent; to suit 40mm min embedment. Refer installation instructions for fixing points
9	N50x3.2mm	Galvanised Jolthead Nail 50x3.2mm	200mm Ctrs Typ

Specifications	
CORE	Infernoguard 30
FRR	-/30/30sm, -/30/-sm
STUD	Masonry
JAMB	J1 (FRR)

Drawn	Roy MACINTYRE	 SOTERIA DOORS Innovative Openings	Edward Street Dargaville 0310 Ph.: 0508 966 378	
Client	Soteria			
Job	-	J1 Fire Resistance Rated Jamb - Masonry Wall Installation		
Drawing Type	Installation			
Job No.	-	 3rd ANGLE PROJECTION	Drawing No.	
ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED TOLERANCES UNLESS OTHERWISE STATED: LINEAR: X - ±1 HOLES: ±0.1 X.X - ±0.1 ANGULAR: X.X - ±0.1° X.XX - ±0.05			Revision	Sheet No.
		© COPYRIGHT	E	1 / 1